



# **ASHRAE Position Document on Filtration and Air Cleaning**

**Approved by ASHRAE Board of Directors  
January 29, 2015**

**Expires  
January 29, 2018**

## COMMITTEE ROSTER

The ASHRAE Position Document on Filtration and Air Cleaning was developed by the Society's Filtration and Air Cleaning Position Document Committee formed on January 6, 2012, with Pawel Wargocki as its chair.

**Pawel Wargocki, Chair**  
Technical University of Denmark  
Kongens Lyngby, Denmark

**Thomas H. Kuehn**  
University of Minnesota  
Minneapolis, MN

**H.E. Barney Burroughs**  
Building Wellness Consultancy, Inc.  
Johns Creek, GA

**Christopher O. Muller**  
Purafil Inc.  
Doraville, GA

**Ernest A. Conrad**  
BOMA International  
Washington DC

**Dean A. Saputa**  
UV Resources  
Santa Clarita, CA

**William J. Fisk**  
Lawrence Berkeley National Laboratory  
Berkeley, CA

**Jeffrey A. Siegel**  
The University of Toronto  
Toronto, ON, Canada

**Mark C. Jackson**  
The University of Texas at Austin  
Austin, TX

**Alan Veeck**  
National Air Filtration Association  
Virginia Beach, VA

Other contributors:

**Dean Tompkins**  
Madison, WI  
for his contribution on photocatalytic oxidizers

**Paul Francisco, Ex-Officio**  
*Cognizant Committee Chair*  
Environmental Health Committee  
University of Illinois  
Champaign, IL

## HISTORY OF REVISION/REAFFIRMATION/WITHDRAWAL DATES

The following summarizes this document's revision, reaffirmation, or withdrawal dates:

01/29/2015—BOD approves Position Document titled Filtration and Air Cleaning

**Note:** ASHRAE's Technology Council and the cognizant committee recommend revision, reaffirmation, or withdrawal every 30 months.

**Note:** ASHRAE position documents are approved by the Board of Directors and express the views of the Society on a specific issue. The purpose of these documents is to provide objective, authoritative background information to persons interested in issues within ASHRAE's expertise, particularly in areas where such information will be helpful in drafting sound public policy. A related purpose is also to serve as an educational tool clarifying ASHRAE's position for its members and professionals, in general, advancing the arts and sciences of HVAC&R.

## CONTENTS

### ASHRAE Position Document on Filtration and Air Cleaning

SECTION	PAGE
Abstract . . . . .	1
Executive Summary . . . . .	2
1 The Issue. . . . .	4
1.1 Justification of Need . . . . .	4
1.2 Purpose and Scope . . . . .	4
2 Background . . . . .	5
2.1 Mechanical and Electronic Air Filters . . . . .	5
2.2 Sorbent Air Cleaners. . . . .	7
2.3 Air Cleaners Using Photocatalytic Oxidation . . . . .	8
2.4 Air Cleaners Using Ultraviolet Germicidal Energy (UV-C). . . . .	10
2.5 Packaged Air Cleaners Using Multiple Technologies . . . . .	11
2.6 Ozone-Generating Air-Cleaning Devices . . . . .	11
2.7 Filtration and Air Cleaning Versus Ventilation . . . . .	12
2.8 Maintenance, Commissioning, and Long-Term Performance of Filtration and Air-Cleaning Devices. . . . .	13
3 Conclusions and Recommendations. . . . .	13
3.1 Summary Statements on Performance of Filtration and Air-Cleaning Devices. . . . .	14
3.2 Positions on the Use of Filtration and Air-Cleaning Devices. . . . .	15
3.3 Recommendations on Future Developments of Filtration and Air-Cleaning Devices. . . . .	15
4 References . . . . .	16
5 Bibliography. . . . .	21

## **ABSTRACT**

Filtration and air cleaning are used to improve indoor air quality and occasionally to enable a reduction in rates of outdoor air ventilation. This Position Document addresses the health consequences of filtration and air cleaning. Data from refereed archival literature are used to form summary statements on performance as well as the positions with respect to specific technologies. One key statement is that, at present, there is only significant evidence of health benefits for porous media particle filtration systems. For a few other technologies, there is evidence to suggest health benefits, but this evidence is not sufficient to formulate firm conclusions. A key position is that filtration and air-cleaning technologies are not recommended for use if they produce significant amounts of contaminants that are known or expected to be harmful for health. Finally, it is stated that there are limited data documenting the effectiveness of gas-phase air cleaning as an alternative to ventilation. ASHRAE should continue supporting research and standardization of contemporary filtration and air-cleaning technologies and should focus on performance testing, maintenance procedures, and development of new innovative technologies.

## EXECUTIVE SUMMARY

ASHRAE needs to address heating-, ventilation-, and air-conditioning- (HVAC) related technologies that change exposures to airborne contaminants harmful for humans. As part of ASHRAE's mission, it is imperative to assess the effectiveness of HVAC technologies in reducing exposures so that the risks for harmful effects on health and comfort are minimized and to establish and promote the Society's positions that will guide ASHRAE membership and the public in technology selection and use. This need applies to filtration and air-cleaning technologies because they traditionally are part of the HVAC system, their use is included and/or required in many guidelines and ventilation standards published by ASHRAE, and they are addressed by technical committees within ASHRAE. Evaluation and guidance are also needed because of the increasing number and variety of filtration and air-cleaning alternatives available on the market and because filtration and air cleaning are considered attractive alternatives to outdoor air ventilation by providing exposure control with less energy use.

Various filtration and air-cleaning technologies are available, depending on the type of contaminants removed and the principle of contaminant removal. This Position Document briefly characterizes these technologies and their applications. The focus is to summarize and examine the existing archival literature describing the direct effects of application of these technologies in public and residential buildings (excluding health-care facilities) on the health of building occupants. Based on the accumulated information, statements on the effectiveness and use of different technologies are proposed and are briefly summarized as follows:

- Mechanical filters have been shown to reduce significantly indoor concentrations of airborne particles. Modest empirical evidence shows that their use will have positive effects on health.
- Electronic filters have been shown to range from being relatively ineffective to very effective at removing indoor airborne particles. Studies of ionizers have shown results ranging from no benefit to some benefit for acute health symptoms.
- There are some sorbent air cleaners that have been shown to substantially reduce the concentrations of gaseous contaminants. There are minimal empirical data that indicate the effects of sorbent air cleaners on health.
- Photocatalytic oxidation technologies have been shown to remove harmful contaminants, to be ineffective in removing contaminants, and/or to generate harmful contaminants during the air-cleaning process. There are no data on how their use affects health.
- Ultraviolet germicidal energy (UV-C) has been shown to inactivate viruses, bacteria, and fungi. A few studies have shown that air-cleaning technologies using UV-C disinfection (also termed *ultraviolet germicidal irradiation* [UVGI]) produce beneficial health effects. There are also studies that have failed to detect health benefits.
- Many types of packaged stand-alone air cleaners using combinations of air-cleaning technologies are available. Scientific data addressing the effects of these air cleaners on health are sparse and inconclusive.
- Negative health effects arise from exposure to ozone and its reaction products. Consequently, devices that use the reactivity of ozone for cleaning the air should not be used in occupied spaces. Extreme caution is warranted when using devices in which ozone is not used for the purpose of air cleaning but is emitted unintentionally during the air-cleaning process as a by-product of their operation.

- There has been much research done on ventilation providing the solution to contamination by dilution, while the body of research on using air cleaning as an effective, energy-saving alternative to ventilation has not been equally large, especially as regards gas-phase air cleaning. Still it should be noted that the information on the effective use of air cleaning as an alternative to ventilation is growing. Limited data exist documenting the effectiveness of air cleaning as an alternative to ventilation. This applies in particular to gas-phase air cleaning. All filtration and air-cleaning technologies should be accompanied by data documenting their performance in removal of contaminants. These data should be based on established industry test standards or third-party evaluations.

The Position Document advocates that ASHRAE lead efforts in research and standardization of filtration and air cleaning. First priority should be given to advancing methods for testing performance of filtration and air-cleaning technologies, in particular the emerging technologies. Second priority should be given to maintenance procedures of filtration and air-cleaning technologies.

## 1. THE ISSUE

### 1.1 Justification of Need

Air in buildings contains various classes of contaminants: particulate matter (some biological in origin), gases, and vapors. Sources for many of these contaminants may be located either indoors (building components, occupants, and occupant activities), outdoors, or both indoors and outdoors. Filtration and air-cleaning technologies are used to reduce exposures to these contaminants in buildings by intentionally removing them from the air. The contaminants are either physically removed or participate in chemical reactions (i.e., are transformed with the intent of producing innocuous compounds). Different filtration and air-cleaning technologies are in use, depending on the class of contaminants that needs to be removed.

Filtration and air cleaning are methods for reducing exposures to contaminants indoors and thus improving indoor air quality. These methods may create viable alternatives and/or supplements to other methods for exposure reduction by supporting dilution via outdoor air ventilation by ensuring that the outdoor and/or recirculated air supplied indoors by HVAC systems is less contaminated and by improving ventilation efficacy by removing contaminants that have an indoor origin. Because these methods reduce concentrations, and thus, exposures to contaminants, many conclude that their application allows reducing outdoor airflow levels for ventilation; this belief is especially valid when outdoor air is heavily contaminated or is burdened with high humidity and thermal loads and when these technologies can remove contaminants at a lower cost than through ventilation alone.

Abundant published data show the effectiveness of different filtration and air-cleaning technologies in removing contaminants from indoors and outdoors. However, few studies document the direct effects of these technologies on health and their long-term performance, as well as their potential limitations and shortcomings. A recent comprehensive review (Zhang et al., 2011) reaffirms these observations.

### 1.2 Purpose and Scope

This document informs ASHRAE membership and the public about the positive, benign, or negative effects of filtration and air-cleaning technologies on health. Health effects, in the context of this position document, are understood as the effects on biomarkers, quality of life, physiological impact, symptoms, clinical outcomes, or mortality (American Thoracic Society 2000).

The document briefly characterizes the major categories of filtration and air-cleaning technologies, and their applications for removing contaminants from outdoor air brought into buildings and/or indoor air. The air-cleaning effects of plants and new air-cleaning technologies, for which there is very limited scientific and technical literature, are not considered.

The archival studies are reviewed to examine measurable health effects associated with the application of various filtration and air-cleaning technologies in public and residential buildings (excluding health-care facilities) and the extent to which cleaning and filtration technologies can offset ventilation with outdoor air for acceptable indoor air quality.

This document also describes the role and health implications of optimal use of air cleaners and the maintenance and replacement of air-cleaning media. The health issues related to disposal of filters and the elements of air cleaners are not considered.



Packaged stand-alone air cleaners using one or multiple technologies and air-cleaning and filtration systems integrated in the ventilation systems are considered as well as technologies available to and used by commercial or residential consumers.

## 2. BACKGROUND

### 2.1 Mechanical and Electronic Air Filters

**2.1.1 Principles of Efficiency and Use.** Mechanical filters use media with porous structures that contain fibers or stretched membrane material in a variety of fiber sizes, densities, and media extension configurations to remove particles from airstreams. A portion of the particles in the air entering a filter attaches to the media and is removed from the air as it passes through the filter. Removal occurs primarily through particle impaction, interception, and Brownian motion/diffusion, depending on particle size. Some filters have a static electrical charge applied to the media to increase particle removal.

Electronic filters include a wide variety of electrically connected air-cleaning devices that are designed to remove particles from airstreams. Removal typically occurs by electrically charging the particles using corona wires or through generation of ions (e.g., using pin ionizers) and by collecting the particles on oppositely charged deposition plates (precipitators) or by the particles' enhanced removal to a conventional media filter or to room surfaces.

The fraction of particles removed from air passing through the filter is termed *particle removal efficiency* or simply *filter efficiency* or *single-pass filter efficiency* (e.g., provided by the minimum efficiency reporting value [MERV]). For electronic filters that are portable and self-contained, the rate of particle removal from air passing through the filter is expressed as clean air delivery rate (CADR), which is approximately equal to the product of airflow rate and the contaminant removal efficiency. For most technologies, the lowest particle removal efficiency typically occurs for particles with an aerodynamic diameter of approximately 0.2 or 0.3  $\mu\text{m}$ ; the removal efficiency increases above and below this particle size. The efficiency of mechanical and electronic air filters varies with filter design and particle size. The efficiency of electronic air cleaners also depends on how they are maintained.

The overall effectiveness of reducing indoor particle concentrations depends on several factors that are either related or independent of a filtration system such as the following: single-pass particle removal efficiency of the filter, the rate of airflow through the filter, location of the filter, and size of the particles. The latter include outdoor air ventilation rate, rate of deposition to surfaces, and total volume of the indoor space and related air change rate, particularly important for stand-alone (portable) air cleaners (see Section 2.5). Recirculation of indoor air through filters and refiltering blended outdoor air with return air are particularly effective for maximizing filter system effectiveness. Filtering the incoming outdoor air before this air enters the occupied space is effective in reducing indoor air concentrations of outdoor air particles, especially in airtight buildings.

ANSI/ASHRAE Standard 52.2, *Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size* (2012a), provides a method of measuring the particle removal efficiency of particle filters for particles that range in size from 0.3 to 10  $\mu\text{m}$  and provides a scale for ranking filters, based on their particle removal efficiencies, called MERV; similar test methods and ranking scales are also available from other organizations. *Indoor Air Quality Guide: Best Practices for Design, Construction, and Commis-*

sioning (2009a) and Chapter 29 in the 2012 *ASHRAE Handbook—HVAC Systems and Equipment* (2012b) and provide additional information on particle filtration technologies and test methods.

**2.1.2 Evidence on Health Effects.** An extensive body of epidemiological research indicates that death rates, hospital admissions, and asthma exacerbations, as well as other adverse health effects increase with increased concentrations of particles in outdoor air (e.g., Brunekreef and Forsberg 2005; Delfino et al. 2005; Pope and Dockery 2006). Because much of a person's exposure to outdoor air particles occurs indoors and because this exposure can be reduced by filtration, it is reasonable to expect associated health benefits from particle filtration that is effective in removing particles having outdoor origin.

Published relationships between outdoor air particle concentrations and adverse health effects have been used in models to predict the related health benefits of particle filtration. The resulting papers, reviewed by Fisk (2013), indicate substantial health benefits associated with filtration, with benefits generally proportional to the reduction in total exposure to particles less than 2.5  $\mu\text{m}$  in diameter. The models considered numerous health or health-related outcomes, including mortality, cardiac or respiratory-related emergency room visits or hospital admissions, chronic bronchitis, and asthma exacerbation. Because most of these health outcomes occur in a small portion of the population, very large empirical studies would thus be needed to confirm these predictions, and such studies have not been performed. Two studies found statistically significant improvements with filtration in biomarkers that predict future adverse coronary events (as cited in Fisk 2013), providing some empirical support for the model predictions of health benefits.

Many studies have experimentally investigated whether the use of particle filtration systems in homes reduces self-reported symptoms of allergies or asthma or improves related objectively measured health outcomes such as forced expiratory volume or biomarkers of inflammation in people who are allergic or asthmatic. Most of these studies used stand-alone (portable) fan filter systems incorporating high-efficiency particle air (HEPA) filters that can remove particles with a minimum efficiency of 99.97% for 0.3  $\mu\text{m}$  particles. A few studies investigated whether use of particle filtration systems in offices or schools reduce nonspecific self-reported health symptoms, often called sick-building syndrome (SBS) symptoms, in the general population. The origin of the particles removed was not identified. Most of these studies report reduced indoor air particle concentrations of 20% to 80%, and 50% a typical reported value. Nearly all of the studies used mechanical filters. A recent review on the effects of air filtration (Fisk 2013) considered the recently published literature and the results of prior reviews (IOM 2000; Reisman 2001; McDonald et al. 2002; Wood 2002; Sublett et al. 2010; Sublett 2011). It concluded that particle filtration could be modestly effective in reducing adverse allergy and asthma outcomes, particularly in homes with pets. It also concluded that particle filtration systems that deliver filtered air to the breathing zone of sleeping allergic or asthmatic persons might be more consistently effective in improving health than use of room or whole-house filtration systems. The review additionally concluded that the limited available evidence suggests that particle filtration in buildings (homes, offices and schools) is not very effective in reducing acute health symptoms (SBS symptoms) in persons without asthma and allergies.

Several communicable respiratory diseases are transmitted, in part, by inhalation of small airborne particles containing infectious virus or bacteria produced during coughing, sneezing, singing, and talking. The portion of total disease transmission that occurs via this mechanism

is uncertain and debatable. Particle filtration systems can reduce indoor airborne concentrations of these particles by removing them from the airstream but not by inactivating infectious species. Filtration may thereby reduce the incidence of the associated communicable respiratory diseases, provided the airstream transports the particles to the filtration system. The results of modeling suggest that having filters in HVAC systems, relative to having no filters, will substantially decrease the portion of disease transmission caused by these small particles (Azimi and Stephens 2013). However, the model assumptions and inputs have a high level of uncertainty. In addition, experimental data outside of health-care facilities are not available to confirm the predictions; there are no strong studies empirically documenting that filtration reduces respiratory infections in people outside of a health-care environment with highly susceptible patients.

The data on the health consequences of electronic particle air cleaners are sparse, but it is reasonable to expect that electronic air cleaners affect health similarly to mechanical filters of equivalent particle removal performance. There are electronic air cleaners (e.g., ion generators) that produce ozone and thus may cause deleterious health effects, as described in Section 2.6, Ozone-Generating Devices. One class of particle air cleaners, ion generators, has been investigated for its ability to reduce acute health symptoms (SBS symptoms), but the literature is unclear as regards the presence and size of effects on symptoms. Of the eight studies on the subject, there are an approximately equivalent number of findings of a positive effect and of no significant effect (or a negative effect) on one or more SBS symptoms (Hawkins and Barker 1978; Fishman 1981; Laws 1982; Hawkins and Morris 1984; Wyon 1992; Shaughnessy et al. 1994; Rosen and Richardson 1999; Richardson et al. 2001). Variations in sample size, presence or lack of a placebo, and presence of a control group make it difficult to form conclusions that are more definitive.

## 2.2 Sorbent Air Cleaners

**2.2.1 Principles Efficiency, and Use.** Sorbent air cleaners involve physical adsorption (physisorption) and chemisorption to remove gaseous contaminants from airstreams. Physisorption is adsorption of gaseous contaminants onto solid porous materials due to Van der Waals forces (nuclear attraction) and condensation in the small pores. This is a reversible process due to relatively weak forces: gases once adsorbed can later desorb back into the airstream. The most common adsorbent used is activated carbon; others include activated aluminas (aluminum oxides), natural and synthetic zeolites in granular form, oxides of silicon, molecular sieves, and various polymers. Chemisorption involves both adsorption and instantaneous irreversible chemical reactions on the sorbent surface to which specific chemical additives or impregnates are added during the manufacturing process to make them more or less specific for individual contaminants or contaminant types (e.g., acid gases). Common adsorbents include activated alumina impregnated with potassium or sodium permanganate and activated carbons impregnated with acidic or basic compounds. Desorption of target contaminants, once adsorbed and chemically reacted, does not occur.

An air-cleaning system using a single gas-phase (or dry-scrubbing) air-filtration medium may not be adequate for the control of multiple contaminants (Muller and England 1994, 1995). Thus, it is common to have a system that uses a combination of both physical and chemisorptive media to provide removal of a wide range of gaseous contaminants.

Adsorbent materials do not adsorb all contaminants equally. The adsorption capacity for nonpolar organics increases with the boiling point, molecular weight, and concentration of the

air contaminant. Low molecular weight (less than 50 u [previously termed amu]) and/or highly polar compounds such as formaldehyde, methane, ethanol, etc., will not be readily adsorbed at low concentrations. Compounds with molecular weight >80 u and nonpolar compounds may be preferentially adsorbed over lower molecular weight and polar compounds. In physical adsorption, polar gas molecules are best removed by polar adsorbents, while nonpolar adsorbents are best for removing nonpolar gases (e.g., activated carbon has a nonpolar surface). The initially adsorbed compounds with lower molecular weight and nonpolar compounds may also be desorbed when a higher molecular weight and polar compounds are present through competitive adsorption. A sufficient depth of sorbent bed may re-adsorb some displaced molecules.

Adsorbent-based systems can remove a broad range of contaminants with moderate to high efficiency. The net rate of adsorption depends on the rate at which contaminant molecules reach the surface of the media, the percentage of those making contact, which are adsorbed, and the rate of desorption.

Some evidence is available on the long-term performance of sorbents in commercial buildings in studies that have examined the performance and effectiveness of air-cleaning systems that have been in continuous use for up to 30 years (Bayer et al. 2009; Lamping and Muller 2009; Burroughs et al. 2013). Relatively accurate estimates of sorbent lifetimes can be obtained when target contaminants are identified and by using their known or expected concentrations in air and the individual removal capacities for each (Muller 2012). Actual sorbent life may be determined by taking periodic samples for life testing or through direct contaminant monitoring. More often, though, sorbents are replaced based on routine maintenance cycles or fiscal considerations. Although there exist physisorbents that may be regenerated, this is not economically viable for the amounts typically contained in commercial HVAC systems and portable air cleaners; thus, they need to be periodically replaced.

Other details regarding removal of gaseous air contaminants can be found in *ASHRAE Handbook—HVAC Applications*, Chapter 45, Control of Gaseous Indoor Air Contaminants (2011) and in *ASHRAE Handbook—Fundamentals*, Chapter 11, Air Contaminants (2013a).

**2.2.2 Evidence on Health Effects.** At present, almost no empirical data are available to enable drawing conclusions about the health benefits of using sorbents in typical buildings, other than anecdotal data describing ancillary benefits of air cleaning on elementary school studies and human embryos (Cohen et al. 1997; Hall et al. 1998; Lamping et al. 2009).

There are, on the other hand, data from laboratory studies that investigated the effects of sorbent air cleaning on initial perceptions of air quality immediately upon entering a laboratory or upon smelling air drawn from a test system (i.e., on perceptions of unadapted individuals, such as visitors to a space, and not on perceptions of adapted persons, such as occupants staying for an extended time in a space) (e.g., Shaughnessy et al. 1994; Fang et al. 2008; Bekö et al. 2008, 2009). These studies showed significantly improved ratings of acceptability or satisfaction with air quality and odor intensities with sorbents. Although perception of air quality comfort is not a health outcome, it may be considered an indicator of a potential subsequent effects of exposures on health.

## 2.3 Air Cleaners Using Photocatalytic Oxidation

**2.3.1 Principles Efficiency and Use.** *Photocatalytic oxidation* (PCO) is defined as a light-mediated, redox reaction of gases and biological particles adsorbed on the surface of a solid pure or doped metal oxide semiconductor material or photocatalyst. The most common

photocatalyst is  $\text{TiO}_2$  (titanium dioxide), while zinc oxide ( $\text{ZnO}$ ), tungsten trioxide ( $\text{WO}_3$ ), zirconium dioxide ( $\text{ZrO}_2$ ), cadmium sulfide ( $\text{CdS}$ ), and iron (III) ( $\text{Fe(III)}$ )-doped  $\text{TiO}_2$ , among others, are also used. Dopants (e.g., iron [Fe], platinum [Pt], silver [Ag]) can have a beneficial effect on the performance of the metal oxide photocatalyst. The photocatalyst generates oxygen species (or reactive oxygen species [ROS]) that remain surface-bound when exposed to light of particular wavelengths in the ultraviolet (UV) range. The oxygen species are highly reactive with adsorbed gases and biological particles. A variety of UV light sources can be used in PCO, including black lights (UV-A: long-wave; 400 to 315 nm), germicidal lamps (UV-C: short-wave; 280 to 200 nm), and lamps that generate ozone (vacuum UV [UV-V]: under 200 nm). Under reaction conditions allowing for deep oxidation (referred to as mineralization), carbon, hydrogen, and oxygen atoms in the reacting species are converted completely via chemical reaction to water vapor and carbon dioxide. In case the conditions do not promote deep oxidation, for example, due to insufficient residence time because of increased airflow through reactor or the presence of halogenated compounds, PCO can produce intermediate species (by-products) that remain bound to the surface of the photocatalyst or desorb and become airborne.

Nearly all organic, gaseous indoor air contaminants and microbes are subject to PCO decomposition (e.g., Zhang et al. 2011; Dalrymple et al. 2010). The efficiency of catalytic oxidizers depends partially on the functional group of contaminants passing through the PCO device. Higher efficiency is observed for oxygenated compounds such as alcohols, ketones, and some aldehydes; intermediate efficiency for aromatics; and lower efficiencies for chlorocarbons. The PCO conversion rates (or fraction of contaminant removed in a single pass) vary depending on the contaminant and the system design from 0% to nearly 100%, with longer residence times needed to achieve higher (single-pass) efficiencies. Efficiencies of PCO air cleaners and by-products formed by them depend on the design of the device, the indoor air setting (e.g., contaminant composition, relative humidity, temperature) in which they are used, and how the device is maintained.

A systematic parametric evaluation of several performance variables was reported for two styles of PCO air filters:  $\text{TiO}_2$  coated on fiberglass fibers ( $\text{TiO}_2/\text{FGFs}$ ) and  $\text{TiO}_2$  coated on carbon cloth fibers ( $\text{TiO}_2/\text{CCFs}$ ) (Zhong et al. 2013). The contaminant destruction rates varied with contaminant class and type of UV source, while formation of by-products correlated with PCO reaction mechanisms for each VOC.

The advantages of PCO are the relatively low pressure drop, ability to treat a wide variety of compounds, and theoretically long life cycle of the reactive process (the self-cleaning or regenerating feature of a photocatalyst). The disadvantages include the lamp energy, lamp replacement costs, and the likelihood of ozone generation depending on lamp source employed (e.g. UV-V lamps ~185 nm produces ozone ( $\text{O}_3$ )). (It has been shown by Ohtani et al. [1992] that irradiation greater than 200 nm and less than 400 nm, in particular UV-C (254 nm), over  $\text{TiO}_2$  will decompose  $\text{O}_3$ ). There is also the potential of an incomplete oxidizing process, which produces by-products of reaction that can be more toxic or harmful than the original constituents (e.g., formaldehyde). The catalysts can be contaminated (poisoned) by airborne reagents and/or products of oxidation, which results in reduced or total efficiency failure of the process. Incomplete decomposition of some organic contaminants and net production of formaldehyde, acetaldehyde, formic acid, and acetic acid were shown by Hodgson et al. (2007), who investigated PCO using mixtures of up to 27 organic contaminants in concentrations reflecting the levels typically occurring indoors. Chemisorbent media positioned downstream of a UVPCO air cleaner effectively counteracted the generation of aldehydes due to incomplete oxidation of volatile organic compounds (VOCs) in UVPCO reactors (Hodgson et al. 2007).

Other details about PCO can be found in reviews (e.g., Mo et al. 2009) as well as ASHRAE RP-1134 (Tompkins et al. 2005).

**2.3.2 Evidence on Health Effects.** No studies are available with respect to the direct health effects associated with the use of PCO air-cleaning equipment in indoor environments. Some studies looked at the effects of PCO on perceived air quality, which, as mentioned above, may be considered as an indicator of potential subsequent effects of exposures on health. These studies found significant reductions in the percentages of persons dissatisfied with air quality in rooms contaminated by nonhuman sources of contamination during operation of PCO (Kolarik and Wargocki 2010; Kolarik et al. 2010). However, when the air was contaminated by human bioeffluents, the percentages of persons dissatisfied with air quality significantly increased, suggesting that the air quality was considerably worsened (Kolarik and Wargocki 2010). It was suggested that the alcohols that are a major part of human bioeffluents and their incomplete oxidation are responsible for the observed results.

## 2.4 Air Cleaners Using Ultraviolet Germicidal Energy (UV-C)

**2.4.1 Principles of Efficiency and Use.** Ultraviolet (UV-C) disinfection (also called *ultraviolet germicidal irradiation* [UVGI]) is used to degrade organic material and inactivate microorganisms. The system is not a filter; thus, inactive particles remain in the airstream, which, in the case of dead fungal spores, may still cause a negative human response to their integral mycotoxins. The most effective wavelength range for inactivation of microorganisms is between 220 and 300 nm, with peak effectiveness near 265 nm. The typical source of UV-C in commercial and residential air and water systems is low-pressure mercury vapor lamps, which emit mainly near-optimal 253.7 nm. UV-C systems may be installed inside HVAC systems, irradiate air near the ceiling, or be incorporated in a stand-alone (portable) air cleaner.

The effectiveness of a UV-C system to inactivate microorganisms in the air and/or on surfaces has been amply demonstrated; the best results were obtained for the long-term irradiation of downstream coil surfaces to avoid fungal amplification on wet surfaces. Experience suggests that control of a moving airstream does not provide favorable killing rates because of the short dwell time. Under ideal conditions, inactivation and/or killing rates of 90% or higher can be achieved but depend on the following: the type of microbial contaminant; specific species; physical or mechanical factors such as UV-C intensity, exposure/dwell time, lamp distance and placement, and lamp life cycle and cleanliness; air movement and patterns; temperature; relative humidity; and air mixing. Airborne removal is best applied in conjunction with filtration of particles with prefiltration in order to protect lamps and mechanical filtration downstream for microbial particles.

Proposed ASHRAE Standard 185.1 provides a method for testing UV-C lights for use in air-handling units or air ducts to inactivate airborne microorganisms, and ASHRAE Standard 185.2-2014 provides a method of testing ultraviolet lamps for use in HVAC units or air ducts to inactivate microorganisms on irradiated surfaces.

Chapter 17 in the 2012 *ASHRAE Handbook—HVAC Systems and Equipment* (2012b) provides additional information on ultraviolet lamp systems.

**2.4.2 Evidence on Health Effects.** Several studies have addressed the application of UV-C systems in health-care facilities. Some of these studies show health benefits for highly susceptible patients (Miller et al. 2002; CDC/NIOSH 2009; Memarzadeh et al. 2010). However, there

is limited evidence on the direct effects of UV-C on health, particularly when applied outside of health-care settings. Menzies et al. (2003) showed a significant reduction in work-related, self-reported acute health symptoms (SBS symptoms) when the UV-C system in ventilation ducts was irradiating cooling coils and drain pans, compared to when it was powered off. Bernstein et al. (2006) irradiated particles (not the cooling coils or drain pans) using UV-C systems in air moving through the ventilation ducts of homes of mold-sensitized, allergic children. Operation of UV-C, relative to a placebo system containing a blue light produced significant alleviation of several asthma outcomes. Upper-room air UV-C systems applied in studies in schools, military barracks, and homeless shelters provide inconsistent effects on tuberculosis, measles, influenza, and common colds (Kowalski 2009).

Fungal contamination found in ventilation systems may contribute to fungal infections in individuals with compromised immune systems, may release contaminants to occupied spaces (Ahearn et al. 1997; Ezeonu et al. 1994; Levetin et al. 2001; Mahoney et al. 1979; Mendell and Smith 1990; Samson 1985), and may possibly contribute to SBS symptoms and other building-related diseases, such as hypersensitivity pneumonitis, allergic rhinitis, and asthma exacerbation (Burge 1990; Lacey 1991; Levetin 1985). UV-C has been shown to be effective in reduction of microbial and endotoxin agents (Menzies et al. 2003), which can breed and accumulate in ventilation systems, especially where condensation of water vapor occurs; however, no direct evidence of health benefits exists other than the study cited above (Menzies et al. 2003).

UV-C systems have been shown to reduce tuberculosis infection in guinea pigs housed in cages ventilated with air drawn from tuberculosis wards (Riley et al. 1957, 1962; Escombe et al. 2009). In the laboratory studies, UV-C has been effective in removing bacterial aerosols and viral aerosols (Xu et al. 2003). To this end, UV-C for upper air, in-duct, and in-room systems was named by ASHRAE's 2014 *Position Document on Airborne Infectious Diseases* as among the two highest research priorities for developing engineering control to reduce infectious disease transmission (ASHRAE 2014b).

## 2.5 Packaged Air Cleaners Using Multiple Technologies

Many air-cleaning devices use a combination of filters (i.e., particle air-cleaning technologies and gas-phase air-cleaning technologies). The devices are often stand-alone (portable), incorporate a fan, and are intended for residential use. These devices are frequently called *air purifiers* or *clean-air delivery (CAD) devices*, but many other names are used as well.

Many packaged air cleaners using multiple technologies are tested using the protocol of the Association of Home Appliance Manufacturers (AHAM) (AHAM 2013) to determine performance reported as the clean-air delivery rate (CADR) for specific contaminants (usually dust, tobacco smoke, and pollen). The performance is a function of the inherent efficiency of the air-cleaning technologies used and the device airflow rate, as well as the indoor setting (see previous sections [Sections 2.1 to 2.4] for the factors influencing effectiveness of air cleaning process).

Presently, minimal data are available on the health consequences of using packaged air cleaners employing multiple technologies.

## 2.6 Ozone-Generating Air-Cleaning Devices

Certain air cleaners produce ozone by design to achieve air-cleaning effects and the removal of contaminants. Additionally, ozone can be produced as a by-product of air-cleaning processes. Any air-cleaning device that uses electricity during air cleaning process has the potential to generate ozone. In practice, ozone generation is associated with air cleaners that

use high-voltage coronas or pin ionizers (e.g., some precipitators or ionizers), UV light of a sufficiently small wavelength (some photocatalytic oxidizers and UV-C air cleaners), and by some plasma air cleaners. Packaged air cleaners employing different air-cleaning technologies may use or produce ozone; examples include ozone generators or ionizers.

Ozone is harmful for health and exposure to ozone creates risk for a variety of symptoms and diseases associated with the respiratory tract (Koren et al. 1989; Touloumi et al. 1997; Bell et al. 2004). Many products of ozone homogeneous and heterogeneous reaction processes also create risks for health, including formaldehyde, unsaturated aldehydes (produced during the reaction of ozone with ketones and alcohols), and ultrafine particles (secondary organic aerosols) (Weschler 2006).

Ozone emission is thus undesirable. However, there is no consensus on the safe level of ozone. For example, ASHRAE's Environmental Health Committee (2011b) issued an emerging issue brief suggesting "safe ozone levels would be lower than 10 ppb" and that "the introduction of ozone to indoor spaces should be reduced to as low as reasonably achievable (ALARA) levels." Still, even widely used guidelines are not entirely consistent with all available epidemiological literature on the effects of ozone, and there is relatively little known about the long-term effects of exposure to low concentrations of ozone.

The current state of the science regarding the health effects of ozone strongly suggests that the use of air cleaners that emit ozone by design should not be permitted; the same information and advice is given by the U.S. EPA, among others (EPA 2013). There is more uncertainty about recommendations for air cleaners that do not use ozone by design for air cleaning but produce ozone unintentionally, as a by-product of their operation. There are devices that emit ozone but at the same time reduce concentrations of other harmful contaminants. The state of the science does not allow making highly certain trade-offs between increased exposure to ozone and the ozone reaction by-products and reduced exposure to other contaminants.

In the absence of robust information regarding safe levels of ozone, the precautionary principle should be used. Any ozone emission (beyond a trivial amount that any electrical device can emit) should be seen as a negative and use of an ozone-emitting air cleaner, even though the ozone is an unintentional by-product of operation, may represent a net negative impact on indoor air quality and thus should be used with caution. If possible, non-ozone-emitting alternatives should be used.

Attention must be paid to certain air-cleaning technologies that claim to produce radicals (e.g., hydroperoxy, peroxy, and hydroxyl radicals) that become airborne (gaseous state) as a means of effecting air cleaning/treatment. These species are ROS and are well known to be very short-lived in the gas-phase (airborne). Few studies in the peer-reviewed literature, if any, have measured these radicals in the gas phase as a means of an effective air treatment with such air-cleaning technologies.

## **2.7 Filtration and Air Cleaning Versus Ventilation**

Filtration and air cleaning reduce exposures to selected air contaminants generated indoors, similar to outdoor air ventilation. Unlike ventilation, these methods can also reduce exposures to contaminants in outdoor air. The effectiveness of filtration and air cleaning is frequently expressed as the equivalent rate of outdoor air ventilation intake flow that would have to be provided to achieve the same effect. However, unlike outdoor air ventilation (essentially reducing concentrations and exposure to the majority of indoor-generated contaminants), filters and air cleaners (unless integrated) deal with one group of contaminants: either with particles, some



types of gases, or microbial contaminants. The effectiveness is consequently the removal efficiency for a single contaminant, a class of contaminants, or a mixture of contaminants (Zhang et al. 2011).

To be expedient, the size of the effect obtained by filtration and air cleaning must be weighed against efficiency of other removal mechanisms (Nazaroff 2000) (i.e., outdoor air ventilation and removal by deposition to surface, see Section 2.1.1). For example, in the case of portable household electric room air cleaners, the product of single-pass efficiency and airflow due to air cleaning should be four times the sum of removal by ventilation and by deposition to meet the target of 80% continuous removal of particles (i.e., 20% or less of the initial particle load in a room, as defined by AHAM Air Cleaner Council [2013]). Furthermore, the cost and energy implications must be taken into account when comparing the effect obtained by filtration and air cleaning with outdoor air ventilation.

The Indoor Air Quality (IAQ) Procedure of ASHRAE Standard 62.1 (2013b) allows that filtration and air cleaning, together with recirculation, can be used as a substitute for a portion of outdoor air ventilation. This is conditional upon detailed analysis of contaminant sources, rates of contaminant removal by air-cleaning systems, contaminant concentration targets, and perceived acceptability targets (Burroughs 2006; Lamping and Stanley 2008; Grimsrud et al. 1999, 2011; Stanley et al. 2007; Dutton et al. 2013). There is, however, only limited scientific evidence showing that outdoor air ventilation intake flow can be partially or completely replaced by filtration and air cleaning.

One consideration that warrants discussion is that the overlap between contaminants with indoor sources versus those with external (outdoor) sources is relatively small and the use of increased ventilation air without filtration and air cleaning can result in substituting one set of contaminants (internally generated) with a different set (externally generated) with any associated health effects. This is especially important in regions that do not meet national or regional air quality standards for one or more criteria pollutants (i.e., ozone, PM<sub>10</sub>, PM<sub>2.5</sub>) or where there may be local sources of air pollution. In these instances outdoor ventilation air should be cleaned before being introduced into the building.

## **2.8 Maintenance, Commissioning, and Long-Term Performance of Filtration and Air-Cleaning Devices**

At the design phase, filters and air cleaners are generally assumed to be installed and operating correctly. In actual installations, there could be air and contaminant bypass around air-cleaning devices (Ward and Siegel 2005), degradation in the performance of some technologies over time (Lehtimäki et al. 2002), and potential for the emission of primary and/or secondary by-products (Zhao et al. 2007; Rim et al. 2013).

Commissioning, active maintenance, and monitoring of filtration and air-cleaning devices are needed to ensure design performance. Additionally, filtration and air cleaners should be tested for extended durations to examine the possible change of performance in time of operation and the minimum period at which regular performance checks should be made. Information on these aspects is nearly nonexistent, and there are nearly no documents regulating and necessitating examination of long-term performance of filtration and air cleaning devices.

*Indoor Air Quality Guide: Best Practices for Design, Construction, and Commissioning* (ASHRAE 2009a), as well as NAFA's *Installation, Operation and Maintenance of Air Filtration Systems* (2012), provides guidance on maintenance and commissioning of filtration and air cleaning.

### 3. CONCLUSIONS AND RECOMMENDATIONS

#### 3.1 Summary Statements on Performance of Filtration and Air-Cleaning Devices

The following statements on filtration and air cleaning are proposed taking into account the evidence in the literature on their effects on health outcomes in public and residential buildings (excluding health-care facilities which were briefly summarized in the preceding chapters). The positions do not define minimum efficiency levels at which the effect of filtration and air cleaning can be regarded as providing health benefits, because the magnitude of the effects obtained by filtration and air-cleaning technologies depends on the design, operation, and setting in which these technologies are operated in a building. Also, in many cases there are no thresholds available for health effects, and regulatory exposure limits vary greatly among different cognizant authorities. Finally, the statements do not take any position on whether certain types of filtration and air-cleaning technologies should or should not be used in the built environment and under which conditions (except the position on ozone-generating devices and the long-term performance of filtration and air-cleaning devices); it was not the objective of the present document. It is regarded that the decision on this matter belongs to other committees setting out regulatory and guiding documents (codes, standards, and guidelines).

- Filtration technologies, in which particles are removed by attaching them to the media (often called *mechanical* or *media filters*), have been documented to be capable in many cases of reducing particle concentrations substantially, including reductions from levels being above to levels being below the associated regulatory exposure limits for reducing health risk set by recognized cognizant authorities. Modest empirical evidence suggests that mechanical filters will have positive effects on health, especially for reducing adverse allergy or asthma outcomes, but not on acute health symptoms in the general population, often called *sick-building syndrome (SBS) symptoms*. Models predict large reductions in morbidity and mortality associated with reduction of indoor exposures to particles from outdoor air, but these health benefits have not been verified empirically.
- Filtration technologies that generate electrical fields and/or ions, often called *electronic filters*, have been documented to range from relatively ineffective to very effective in reducing particles substantially, including reductions from levels being above to levels being below the associated regulatory exposure limits for reducing health risks set by recognized cognizant authorities. Within this broad characterization of air cleaners, ionizers have been evaluated to either show benefits or no benefits for acute health symptoms. Many electronic air cleaners emit significant ozone and are thus subject to special attention as advised by Position 1 in Section 3.2.
- There are sorbent air cleaners that have been documented to reduce concentrations of harmful gaseous contaminants substantially, including reductions from levels being above to levels being below the associated regulatory exposure limits for reducing health risks set by recognized cognizant authorities. There are very limited data on long-term effectiveness of these air cleaners for indoor air applications with mixtures of contaminants at low concentrations. Minimal empirical data exist on the health effects of using sorbent-based air-cleaning technologies.
- Air cleaners using photocatalytic oxidation (PCO) have been documented to remove harmful contaminants to levels being below the associated regulatory exposure limits for reducing health risks set by recognized cognizant authorities. However, there are PCO

technologies that are ineffective in reducing concentrations significantly, and there are PCO technologies that have also been shown to generate harmful contaminants during the air-cleaning process. No empirical data exist on the health effects of using PCO technologies. Different UV lamps used in many PCO devices can emit significant ozone and are thus subject to special attention as advised by Position 1 in Section 3.2.

- Short-wave ultraviolet (UV-C) energy has been documented to inactivate viruses, bacteria, and fungi. Some air-cleaning technologies using UV-C disinfection (also termed *ultra-violet germicidal irradiation* [UVGI]) have been documented, in a few studies, to show beneficial health effects when upper-room air, ventilation ducts, and evaporator coil surfaces were irradiated with UV-C. Some studies have failed to detect health benefits. Some UV lamps can emit significant ozone and are thus subject to special attention as advised by Position 1 in Section 3.2.
- Packaged air cleaners using multiple filtration and air-cleaning technologies are room air appliances intended for residential and small-space application. Their performance is subject to the advantages and disadvantages of the filtration and air-cleaning technology incorporated within the devices. Scientific documentation of the health effects of these devices on occupants is sparse and inconclusive. Some of the technologies incorporated into these devices either produce or rely on ozone for application and are thus subject to special attention as advised by Position 1 in Section 3.2.
- Filtration and air-cleaning technologies are often regarded as an attractive alternative to ventilation, enabling a reduction of outdoor air ventilation rate. The Indoor Air Quality (IAQ) Procedure of ASHRAE Standard 62.1 allows lower ventilation rates if alternative methods are used to reduce exposures to contaminants of concern, including the use of filtration or air cleaning. Limited data exist documenting the effectiveness of air cleaning, in particular gas-phase air cleaning, as an alternative to ventilation.

### **3.2 Positions on the Use of Filtration and Air-Cleaning Devices**

ASHRAE holds the following positions on filtration and air-cleaning devices:

1. Devices that use the reactivity of ozone for the purpose of cleaning the air should not be used in occupied spaces because of negative health effects that arise from exposure to ozone and its reaction products. Extreme caution is warranted when using devices that emit a significant amount of ozone as by-product of their operation, rather than as a method of air cleaning. These devices pose a potential risk to health.
2. All filtration and air-cleaning technologies should be accompanied by data documenting their performance regarding removal of contaminants; these data should be based on established industry test standards. If not available, scientifically controlled third-party evaluation and documentation should be provided.

### **3.3 Recommendations on Future Developments of Filtration and Air-Cleaning Devices**

Further development of filtration and air cleaning is needed, particularly in the following areas:

1. Quality control of operation of filtration and air-cleaning technologies, especially regarding data on their long-term performance.
2. Development of regulatory and guiding documents supporting design, operation, and maintenance of filtration and air cleaning devices.

3. Modification of methods of charging particles by electronic air cleaners to reduce the generation of ozone.
4. Integration of different filtration and air-cleaning technologies.
5. Development of air-cleaning technologies that support ventilation by removing air contaminants for which ventilation is less effective, such as proven and practical systems for removing ozone and possibly other gaseous pollutants from the air entering buildings.
6. Research on and application of intermittent use of filtration and air cleaners to deal with peak loads or unexpected releases of contaminants.
7. The extent to which air cleaning can enable reduction in outdoor air ventilation rates.

#### 4. REFERENCES

- AHAM. 2013. ANSI/AHAM AC-1, *The Method for Measuring Performance of Portable Household Electric Cord-Connected Room Air Cleaners*. New York: American National Standards Institute.
- Ahearn, D.G., S.A. Crow, R.B. Simmons, D.L. Price, S.K. Mishra, and D.L. Pierson. 1997. Fungal colonization of air filters and insulation in a multi-story office building: production of volatile organics. *Current Microbiology* 35:305–8.
- American Thoracic Society. 2000. What constitutes an adverse health effect of air pollution? *American Journal of Respiratory and Critical Care Medicine* 161.
- ASHRAE. 2009a. *Indoor Air Quality Guide: Best Practices for Design, Construction, and Commissioning*. Atlanta: ASHRAE.
- ASHRAE. 2009c. *Indoor Air Quality Guide: Best Practices for Design, Construction, and Commissioning*. Atlanta: ASHRAE.
- ASHRAE. 2011a. *ASHRAE Handbook—HVAC Applications*, Chapter 45, Control of Gaseous Indoor Air Contaminants. Atlanta: ASHRAE.
- ASHRAE. 2011b. Environmental Health Committee (EHC) Emerging Issue Report: Ozone and Indoor Chemistry. Atlanta: ASHRAE.
- ASHRAE. 2012a. ANSI/ASHRAE Standard 52.2-2012, *Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size*. Atlanta: ASHRAE.
- ASHRAE. 2012b. *ASHRAE Handbook—HVAC Systems and Equipment*. Chapter 29, Air Cleaners for Particulate Contaminants. Atlanta: ASHRAE.
- ASHRAE. 2013a. *ASHRAE Handbook—Fundamentals*, Chapter 11, Air Contaminants. Atlanta: ASHRAE.
- ASHRAE. 2013b. ANSI/ASHRAE Standard 62.1-2013, *Ventilation for Acceptable Indoor Air Quality*. Atlanta: ASHRAE.
- ASHRAE. 2014a. ANSI/ASHRAE Standard 185.2, *Method of Testing Ultraviolet Lamps for Use in HVAC&R Units or Air Ducts to Inactivate Microorganisms on Irradiated Surfaces*. Atlanta: ASHRAE.
- ASHRAE. 2014b. *Position Document on Airborne Infectious Diseases*. Atlanta: ASHRAE.
- AWWA. 1971. *Water Quality and Treatment*. McGraw-Hill, New York.
- Azimi, P. and B. Stephens. 2013. HVAC filtration for controlling infectious airborne disease transmission in indoor environments: Predicting risk reductions and operational costs. *Building and Environment* 70:150–60.
- Bayer, C.W., H.E. Burroughs, and C. Muller. 2009. Demonstration of ASHRAE IAQ-procedure effectiveness for improved IAQ and greater energy efficiency. *Proceedings of Healthy*

*Buildings 2009, the 9th International Healthy Buildings Conference and Exhibition.* Syracuse, NY.

- Bekö, G., G. Clausen, and C.J. Weschler. 2008. Sensory pollution from bag filters, carbon filters and combinations. *Indoor Air* 18:27–36.
- Bekö, G., M.O. Fadeyi, G. Clausen, and C.J. Weschler. 2009. Sensory pollution from bag-type fiberglass ventilation filters: Conventional filter compared with filters containing various amounts of activated carbon. *Building and Environment* 44: 2114–20.
- Bell, M.L., A. McDermott, S.L. Zeger, J.M. Samet, and F. Dominici. 2004. Ozone and short-term mortality in 95 US urban communities, 1987–2000. *Journal of the American Medical Association* 292: 2372–8.
- Bernstein, J.A., R.C. Bobbitt, L. Levin, R. Floyd, M.S. Crandall, R.A. Shalwitz, A. Seth, and M. Glazman. 2006. Health effects of ultraviolet radiation in asthmatic children's homes. *Journal of Asthma* 43:255–62.
- Brunekreef, B., and B. Forsberg. 2005. Epidemiological evidence of effects of coarse airborne particles on health. *European Respiratory Journal* 26:309–18.
- Burge, H. A. 1990. Bioaerosols: Prevalence and health effects in the indoor environment. *Journal of Allergy and Clinical Immunology* 86:687–701.
- Burroughs, H.E. 2006. Role of filtration and air cleaning in sustaining acceptable indoor air quality through ventilation air replacement. Presented at the 2006 EPA Regional, State, and Local Dispersion Modelers' Workshop, May 16–18, San Diego, CA.
- Burroughs, H.E., C. Muller, W.L. Yao, and Q.L. Yu. 2013. An evaluation of filtration and air cleaning equipment performance in existing installations with regard to acceptable IAQ attainment. *Proceedings of ISHVAC 2013, the 8th International Symposium on Heating, Ventilating and Air Conditioning*. 262: 267-275. Xi'an University of Architecture and Technology, Xi'an, China.
- CDC/NIOSH. 2009. *Environmental control for tuberculosis: basic upper-room ultraviolet germicidal irradiation guidelines for healthcare settings*. Atlanta: Centers for Disease Control and Prevention/National Institute for Occupational Safety and Health.
- Cohen, J., Gilligan, A., Esposito, W., Schimmel, T., and Dale, B. 1997. Ambient air and its potential effects on conception in vitro. *Human Reproduction* 12(8):1742—1749.
- Dalrymple, O.K., E. Stefanakos, M.A. Trotz, and D.Y. Goswami. 2010. A review of the mechanisms and modelling of photocatalytic disinfection. *Applied Catalysis B: Environmental* 98:27–38.
- Delfino, R.J., C. Sioutas, and S. Malik. 2005. Potential role of ultrafine particles in associations between airborne particle mass and cardiovascular health. *Environmental Health Perspectives* 113:934–46.
- Dutton, S.M., W.R. Chan, M.J. Mendell, M. Barrios, S. Parthasarathy, M. Sidheswaran, D. Sullivan, E. Eliseeva, and W.J. Fisk. 2013. *Evaluation of the indoor air quality procedure for use in retail buildings*. LBNL-6079E Report. Berkeley: Lawrence Berkeley National Laboratory.
- EPA. 2013. Ozone Generators that are Sold as Air Cleaners. <http://epa.gov/iaq/pubs/ozonegen.html>.
- Escombe, A.R., D.A.J. Moore, R.H. Gilman, M. Navincopa, E. Ticona, B. Mitchell, C. Noakes, and C.A. Evans. 2009. Upper-room ultraviolet light and negative air ionization to prevent tuberculosis transmission. *PLoS Medicine*. 6:e43 DOI: 10.1371/journal.pmed.1000043.

- Ezeonu, I.M., J.A. Noble, R.B. Simmons, D.L. Price, S.A. Crow, and D.G. Ahearn. 1994. Effect of relative humidity on fungal colonization of fiberglass insulation. *Applied and Environmental Microbiology* 60:2149–51.
- Fang, L., G. Zhang, and A. Wisthaler. 2008. Desiccant wheels as gas-phase absorption (GPA) air cleaners: Evaluation by PTR-MS and sensory assessment. *Indoor Air* 18: 375–85.
- Fishman, D.S. 1981. Subjective comfort associated with negative air ions. *Heating & Ventilating Engineer* 13–15.
- Fisk, W.J., H. Destailats, and M.A. Sidheswaran. 2011. Saving energy and improving IAQ through application of advanced air cleaning technologies. *HVAC Journal: REHVA* May:27–9.
- Fisk, W.J. 2013. Health benefits of particle filtration. *Indoor Air*. DOI: 10.1111/ina.12036.
- Grimsrud, D.T., B.B. Bridges, N.G. Carlson, and D.E. Hadlich. 1999. Ventilation requirements in a retail store. *Proceedings of the Indoor Air 99, the 8th International Conference on Indoor Air Quality and Climate*, 8–13. Scotland: Edinburgh.
- Grimsrud, D.T., N. Carlson, B. Bridges, T. Springman, and S. Williams. 2011. *Indoor Air 2011*. Investigation of appropriate ventilation rates for retail stores. CD-ROM. Austin, TX: Paper 961.
- Hall, J., A. Gilligan, T. Schimmel, T. Cecchi, and J. Cohen. 1998. The origin, effects and control of air pollution in laboratories used for human embryo culture. *Human Reproduction* 13(4).
- Hawkins, L.H., and T. Barker. 1978. Air ions and human performance. *Ergonomics* 21:273–8.
- Hawkins, H.L., and L. Morris. 1984. Air ions and the sick building syndrome. *Proceedings of the 3rd International Conference on Indoor Air Quality and Climate*. Sweden: Stockholm.
- Hodgson, A.T., H. Destailats, D.P. Sullivan, and W.J. Fisk. 2007. Performance of ultraviolet photocatalytic oxidation for indoor air cleaning applications. *Indoor Air* 17:305–16.
- IOM. 2000. *Clearing the Air: Asthma and Indoor Air Exposures*. Washington, D.C.: Institute of Medicine, National Academy of Sciences, National Academy Press.
- Kolarik, J., and P. Wargocki. 2010. Can a photocatalytic air purifier improve the perceived air quality indoors? *Indoor Air* 20:255–62.
- Kolarik, B., P. Wargocki, A. Skorek-Osikowska, and A. Wisthaler. 2010. The effect of a photocatalytic air purifier on indoor air quality quantified using different measuring methods. *Building and Environment* 45:1434–40.
- Koren, H.S., R.B. Devlin, D.E. Graham, R. Mann, M.P. Mcgee, D.H. Horstman, W.J. Kozumbo, S. Becker, D.E. House, W.F. McDonnell, and P.A. Bromberg. 1989. Ozone-induced inflammation in the lower airways of human subjects. *American Review of Respiratory Disease* 139:407–15.
- Kowalski, W.J. 2009. *Ultraviolet Germicidal Irradiation Handbook: UVGI for Air and Surface Disinfection*. New York: Springer.
- Lacey, J. 1991. Aerobiology and health: The role of airborne fungal spores in respiratory disease. In D. L. Hawksworth (ed.), *Frontiers in Mycology*. Wallingford: C.A.B. International, Oxon. 157–85.
- Lamping, G.A., D. Rhodes, and R. Clary. 2009. Detecting and Reducing Aerosols to Improve IAQ in the Class-room. *Proceedings of Indoor Air Quality Association—12th Annual Meeting and In-door Air Expo*. TX: Fort Worth.

- Lamping, G.A., and Stanley, W.B.M. 2008. Applying the IAQ Procedure of ASHRAE 62.1-2007 at K-12 Educational Facilities. *Globalcon 2008 Proceedings*. GA: Atlanta.
- Laws, C.A. 1982. Air ions in the working environment. *Heating & Ventilating Engineer* 18–20.
- Lehtimäki, M., A. Säämänen, and A. Taipale. 2002. *Investigation of mechanisms and operating environments that impact the filtration efficiency of charged air filtration media*. Technical Report RP-1189. Atlanta: ASHRAE.
- Levetin, E. 1995. Fungi in H. Burge (ed.), *Bioaerosols*. Boca Raton: Lewis Publishers, CRC Press. 87–120.
- Levetin, E., R. Shaughnessy, C. Rogers, and R. Scheir. 2001. Effectiveness of germicidal UV radiation for reducing fungal contamination within air handling units. *Applied and Environmental Microbiology* 67:3712–5.
- Mahoney, D.H., C.P. Steuber, K.A. Starling, F.F. Barrett, J. Goldberg, and D. J. Fernbach. 1979. An outbreak of aspergillosis in children with acute leukemia. *Journal of Pediatrics* 95:70–2.
- McDonald, E., D. Cook, T. Newman, L. Griffith, G. Cox, and G. Guyatt. 2002. Effect of air filtration systems on asthma: A systematic review of randomized trials. *Chest* 122:1535–42.
- Memarzadeh, F., R.N. Olmsted, and J.M. Bartley. 2010. Applications of ultraviolet germicidal irradiation disinfection in health care facilities: Effective adjunct, but not stand alone technology. *American Journal of Infection Control* 38:13–24.
- Mendell, M.J., and A.H. Smith. 1990. Consistent pattern of elevated symptoms in air-conditioned office buildings: a re-analysis of epidemiologic studies. *American Journal of Public Health* 80:1193–99.
- Menzies, D., J. Popa, J. Hanley, T. Rand, and D. Milton. 2003. Effect of ultraviolet germicidal lights installed in office ventilation systems on workers' health and wellbeing: Double-blind multiple cross over trial. *Lancet* 363:1785–92.
- Miller, S.L., M. Hernandez, K. Fennelly, J. Martyny, J. Macher, E. Kujundzic, P. Xu, P. Fabian, J. Peccia, and C. Howard. 2002. *Efficacy of ultraviolet irradiation in controlling the spread of tuberculosis*. NIOSH final report, Contract 200–97–2602; NTIS publication PB2003-103816. Cincinnati, OH: U.S. Department of Health and Human Services, Centers for Disease Control and Prevention.
- Mo, J., Y. Zhang, Q. Xu, J.J. Lamson, and R. Zhao. 2009. Photocatalytic purification of volatile organic compounds in indoor air: A literature review. *Atmospheric Environment* 43: 2229–46.
- Muller, C. 2012. Is it time to change my media? *Air Pollution Control* 2(1): 28–33.
- Muller, C.O., and W.G. England. 1994 Gas-phase air filtration: Single media or multiple media systems. Which should be used for IAQ applications? *Proceedings of IAQ '94 Conference*. MO: St. Louis.
- Muller, C.O., and W.G. England. 1995. Achieving your indoor air quality goals—Which filtration system works best? *ASHRAE Journal* 37(2):24–31.
- NAFA. 2012. *Installation, Operation and Maintenance of Air Filtration Systems*, 3rd ed. Virginia Beach: National Air Filtration Association.
- Nazaroff, W.W. 2000. Effectiveness of air cleaning technologies. In: *Proceedings of Healthy Buildings 2000* 2:49–54.

- Ohtani, B., S.-W. Zhang, S.-I. Nishimoto, and T. Kagiya. 1992. Catalytic and photocatalytic decomposition of ozone at room temperature over titanium(IV) oxide. *Journal of the Chemical Society, Faraday Transactions* 88(7):1049–1053.
- Pope, C.A., III and D.W. Dockery. 2006. Health effects of fine particulate air pollution: lines that connect. *Journal of the Air & Waste Management Association* 56:709–42.
- Reisman, R.E. 2001. Do air cleaners make a difference in treating allergic disease in homes? *Annals of Allergy, Asthma & Immunology* 87:41–43.
- Richardson, G., D.J. Harwood, S.A. Eick, F. Dobbs, and K.G. Rosen. 2001. Reduction of fine airborne particulates (PM<sub>3</sub>) in a small city centre office, by altering electrostatic forces. *The Science of the Total Environment* 269: 145–55.
- Riley, R.L., W.F. Wells, C.C. Mills, W. Nyka, and R.L. McLean. 1957. Air hygiene in tuberculosis: Quantitative studies of infectivity and control in a pilot ward. *American Review of Tuberculosis and Pulmonary Disease* 75:420–31.
- Riley, R.L., C.C. Mills, F. O'Grady, L.U. Sultan, F. Wittstadt, and D.N. Shivpuri. 1962. Infectiousness of air from a tuberculosis ward. Ultraviolet irradiation of infected air: Comparative infectiousness of different patients. *American Review of Respiratory Disease* 85: 511–25.
- Rim, D., D. Poppendieck, L. Wallace, and A. Persily. 2013. Effectiveness of an in-duct electrostatic precipitator in nanoparticle removal with consideration of ozone emissions. *Proceedings of ASHRAE IAQ 2013*. Canada: Vancouver.
- Rosen, K.G., and G. Richardson. 1999. Would removing indoor air particulates in children's environments reduce rate of absenteeism—A hypothesis. *The Science of the Total Environment* 234:87–93.
- Samson, R.A. 1985. Occurrence of moulds in modern living and working environments. *European Journal of Epidemiology* 1:54–61.
- Shaughnessy, R.J., E. Levetin, J. Blocker, and K.L. Sublette. 1994. Effectiveness of portable indoor air cleaners—Sensory testing results. *Indoor Air* 4:179–88.
- Stanley, W.B.M., and G. Lamping. 2007. Case study: Applying the IAQ procedure with present technology at a high school facility. *Proceedings IAQ 2007 Healthy and Sustainable Buildings*. MD: Baltimore.
- Sublett, J.L., J. Seltzer, R. Burkhead, P.B. Williams, H.J. Wedner, and W. Phipatanakul. 2010. Air filters and air cleaners: Rostrum by the American Academy of Allergy, Asthma & Immunology Indoor Allergen Committee. *Journal of Allergy and Clinical Immunology* 125:32–38.
- Sublett, J.L. 2011. Effectiveness of air filters and air cleaners in allergic respiratory diseases: A review of the recent literature. *Current Allergy and Asthma Reports* 11:395–402.
- Tompkins, D.T., B.J. Lawnicki, W.A. Zeltner, and M.A. Anderson. 2005. Evaluation of photocatalysis for gas-phase air cleaning—Part 1: Process, technical, and sizing considerations. *ASHRAE Transactions* 111:60–84.
- Touloumi, G., K. Katsouyanni, D. Zmirou, J. Schwartz, C. Spix, A.P. Deleon, A. Tobias, P. Quenel, D. Rabaczenko, L. Bacharova, L. Bisanti, J.M. Vonk, and A. Ponka. 1997. Short-term effects of ambient oxidant exposure on mortality: A combined analysis within the APHEA project. *American Journal of Epidemiology* 146:177–85.
- Ward, M., and J.A. Siegel. 2005. Filter bypass: Implications for filter efficiency. *ASHRAE Transactions* 111:1091–100.



- Weschler, C.J. 2006. Ozone's impact on public health: Contributions from indoor exposures to ozone and products of ozone-initiated chemistry. *Environmental Health Perspectives* 114: 1489–96.
- Wood, R.A. 2002. Air filtration devices in the control of indoor allergens. *Current Allergy and Asthma Reports* 2:397–400.
- Wyon, D.P. 1992. Sick buildings and the experimental approach. *Environmental Technology* 13:313–22.
- Xu, P., J. Peccia, P. Fabian, J.W. Martyny, K. Fennelly, M. Hernandez, and S.L. Miller. 2003. Efficacy of ultraviolet germicidal irradiation of upper-room air in inactivating bacterial spores and Mycobacteria in full-scale studies. *Atmospheric Environment* 37:405–19.
- Zhang, Y., J. Mo., Y. Li, J. Sundell, P. Wargocki, J. Zhang, J.C. Little, R. Corsi, Q. Deng, M. Leung, L. Fang, W. Chen, J. Li, and Y. Sun. 2011. Do commonly-used air cleaning technologies improve indoor air quality? A literature review. *Atmospheric Environment* 45:4329–43.
- Zhao, P., J.A. Siegel, and R. Corsi. 2007. Ozone removal by HVAC filters. *Atmospheric Environment* 41:3151–60.
- Zhong, L., F. Haghghat, C-S. Lee, and N. Lakdawala. 2013. Performance of ultraviolet photocatalytic oxidation for indoor air applications: systematic experimental evaluation. *Journal Hazardous Materials* 261:130–38.

## 5. BIBLIOGRAPHY

List of selected research projects sponsored by ASHRAE and dealing with the topic of filtration and air cleaning:

- ASHRAE. 1984. RP-268, *Development of test method for gaseous contamination removal devices*. Atlanta: ASHRAE.
- ASHRAE. 1993. RP-625, *Matching filtration to health requirements, Phase I*. Atlanta: ASHRAE.
- ASHRAE. RP-625, *Matching filtration to health requirements, Phase II*. Atlanta: ASHRAE.
- ASHRAE. 1994. RP-674, *Evaluation Of Gas Phase Air Filtration Equipment As Used In Common Building Applications*. Atlanta: ASHRAE.
- ASHRAE. 2004. RP-791(TRP-1098), *Field test methods to measure gaseous contaminant removal effectiveness of gas phase air filtration equipment*. Atlanta: ASHRAE.
- ASHRAE. 1997. RP-792, *Evaluation of test methods for determining the effectiveness and capacity of gas phase air filtration equipment for indoor air applications (Phase II)*. Atlanta: ASHRAE.
- ASHRAE. 1995. RP-804, *Identification Of Contaminants, Exposures, Effect And Control Options For Construction/Renovation Activities, Phase I*. Atlanta: ASHRAE.
- ASHRAE. 2001. RP-961, *Identification Of Contaminants, Exposures, Effect And Control Options For Construction/ Renovation Activities, Phase II (804-RP)*. Atlanta: ASHRAE.
- ASHRAE. 2004. RP-1098, *Field Test Methods To Measure Contaminant Removal Effectiveness Of Gas Phase Air Filtration Equipment; Phase II Of 791-RP*. Atlanta: ASHRAE.
- ASHRAE. 2003. RP-1134, *Evaluation Of Photocatalytic Air-Cleaning Capacity*. Atlanta: ASHRAE.
- ASHRAE. n.d. RP-1457, *By-product Production from Photocatalytic Oxidation Associated with Indoor Air-Cleaning Devices*. Atlanta: ASHRAE.

- ASHRAE. 2013. RP-1557, Evaluation Lab Comparison of Relative Performance of Gas Phase Filtration Media at High and Low Challenge Concentrations. Atlanta: ASHRAE.

List of ASHRAE Standards dealing with filtration and air cleaning:

- ASHRAE. 2008. ANSI/ASHRAE Standard 145.1-2008, *Laboratory Test Method for Assessing the Performance of Gas-Phase Air-Cleaning Systems: Loose Granular Media*. Atlanta: ASHRAE.
- ASHRAE. 2011. ANSI/ASHRAE Standard 145.2-2011, *Laboratory Test Method for Assessing the Performance of Gas-Phase Air-Cleaning Systems: Air-Cleaning Devices*. Atlanta: ASHRAE.
- ASHRAE. 2012. ANSI/ASHRAE Standard 52.2-2012, *Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size*. Atlanta: ASHRAE.
- ASHRAE. 2013. ANSI/ASHRAE Standard 62.2-2013, *Ventilation and Acceptable Indoor Air Quality in Low-Rise Residential Buildings*. Atlanta: ASHRAE.
- ASHRAE. ND. ASHRAE Standard 185.1P, *Method of Testing UVC Lights for use in Air Handling Units or Air Ducts to Inactivate Airborne Microorganisms*. Atlanta: ASHRAE.
- ASHRAE. 2011. ANSI/ASHRAE/USGBC/IES Standard 189.1-2011, *Standard for the Design of High-Performance Green Buildings, Except Low-rise Residential Buildings*. Atlanta: ASHRAE.

List of ASHRAE Guidelines and User's Manuals dealing with filtration and air cleaning:

- ASHRAE. 2012. ASHRAE Guideline 26-2012, *Guideline for Field Testing of General Ventilation Filtration Devices and Systems for Removal Efficiency In-Situ by Particle Size and Resistance to Airflow*. Atlanta: ASHRAE.
- ASHRAE. 2010. *62.1 User's Manual*. Atlanta: ASHRAE.
- ASHRAE. 2009. ASHRAE Guideline 29, *Guideline for Risk Management of Public Health and Safety in Buildings*. Atlanta: ASHRAE.
- ASHRAE. 2009. *The Indoor Air Quality Guide: Best Practices for Design, Construction and Commissioning*. Atlanta: ASHRAE.

List of ASHRAE cognizant committees:

- TC 2.3, Gaseous Air Contaminants and Gas Contaminant Removal Equipment
- TC 2.4, Particulate Air Contaminants and Particulate Contaminant Removal Equipment
- SSPC 52.2, Method of Testing General Ventilation Air Cleaning Devices for Removal Efficiency by Particle Size
- SSPC 62.1, Ventilation for Acceptable Indoor Air Quality
- SPC 62.2, Ventilation and Acceptable Indoor Air Quality in Low-Rise Residential Buildings
- SPC 90.1, Energy Standard for Buildings Except Low-Rise Residential Buildings
- SSPC 145, Test Method for Assessing the Performance of Gas Phase Air Cleaning Equipment
- SPC 170, Ventilation of Health Care Facilities
- SPC 180, Standard Practice for Inspection and Maintenance of Commercial-Building HVAC Systems